



Ref. Certif. No.

SG PSB-LE-06477

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic control gear for emergency lighting Emergency module	
Name and address of the applicant	Suzhou Cyantronic Technology Co., Ltd No.1 Shenxiang Road, SND 215151 Suzhou, Jiangsu PEOPLE'S REPUBLIC OF CHINA	
Name and address of the manufacturer	Suzhou Cyantronic Technology Co., Ltd No.1 Shenxiang Road, SND, 215151 Suzhou, Jiangsu, PEOPLE'S REPUBLIC OF CHINA	
Name and address of the factory	Suzhou Cyantronic Technology Co., Ltd No.1 Shenxiang Road, SND, 215151 Suzhou, Jiangsu, PEOPLE'S REPUBLIC OF CHINA	
Ratings and principal characteristics	Rated voltage: Rated frequency: Rated input current: Rated output: Rated duration: tc: Method of installation: Battery:	220-240V~ 50/60Hz See model list See model list See model list 75°C Built-in See model list
Trademark / Brand (if any)	details please see page 2	
Model/type Ref. A sample of the product was tested and found to be in conformity with	details please see page 2 IEC 61347-1:2015 IEC 61347-1:2015/AMD1:2017 IEC 61347-2-7:2011 IEC 61347-2-7:2011/AMD1:2017 IEC 61347-2-7:2011/AMD2:2021	
as shown in the Test Report Ref. No. which forms part of this certificate	083-2409990-000	

Page 1 of 5

This CB Test Certificate is issued by the National Certification Body

CBS 102263 0046 Rev. 00

Date, 2025-01-24

(Yin Ji)

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Trademark / Brand (Image)

CYANTRONIC

Models (continued)

ANI03-30/MC.; ANI01-30/MC; ANI01-30; ANI03-15/MC.;
 ANI03-30.; ANI03-15.; ANI02-30LFP7302-S20;
 ANI03-30/MC/ST.; ANI01-30/MC/ST; ANI01-30/ST;
 ANI03-15/MC/ST.; ANI03-30/ST.; ANI03-15/ST.;
 ANI03-30/MC/DA; ANI03-15/MC/DA; ANI03-30/DA;
 ANI03-15/DA; ANI05-30/MC; ANI08-15/MC; ANI05-15/MC;
 ANI05-30; ANI08-15; ANI05-15; ANI04-30LFP7304-S20;
 ANI05-30/MC/ST; ANI08-15/MC/ST; ANI05-15/MC/ST;
 ANI05-30/ST; ANI08-15/ST; ANI05-15/ST; ANI05-30/MC/DA;
 ANI08-15/MC/DA; ANI05-15/MC/DA; ANI05-30/DA;
 ANI08-15/DA; ANI05-15/DA; AI03-30/MC; AI03-15/MC;
 AI01-30/MC; AI01-30; AI03-30; AI03-15; AI03-30/MC/ST.;
 AI01-30/MC/ST; AI01-30/ST; AI03-15/MC/ST; AI03-30/ST.;
 AI03-15/ST; AI03-30/MC/DA; AI03-15/MC/DA; AI03-30/DA;
 AI03-15/DA; AI02-30LFP7302-S20; AI05-30/MC; AI05-15/MC;
 AI05-30; AI05-15; AI05-30/MC/ST; AI05-15/MC/ST;
 AI05-30/ST; AI05-15/ST; AI05-30/MC/DA; AI05-15/MC/DA;
 AI05-30/DA; AI05-15/DA; AI04-30LFP7304-S20

Model list:

Model	Internal Code	Rated Input Current (mA)	Battery	Rated output				Duration (h)
				Output Voltage (VDC)	Emergency (mA)	Rated (W)	U-OUT (VDC)	
ANI03-30/MC.	9010330365	Max. 19	2IFpR19/66 2.0Ah 6.4V	30-300	8-80	3	310	3
ANI01-30/MC	9010130165	Max. 19	2IFpR19/66 2.0Ah 6.4V	30-300	8-80	3	310	3
ANI01-30	9010330385	Max. 19	2IFpR19/66 2.0Ah 6.4V	30-300	8-80	3	310	3
ANI03-15/MC.	9010310165	Max. 19	2IFpR19/66 2.0Ah 6.4V	30-300	8-80	3	310	1.5
ANI03-30.	9010330385	Max. 19	2IFpR19/66 2.0Ah 6.4V	30-300	8-80	3	310	3
ANI03-15.	9010310185	Max. 19	2IFpR19/66 2.0Ah 6.4V	30-300	8-80	3	310	1.5
ANI02-30LFP7302-S20	9010330385	Max. 19	2IFpR19/66 2.0Ah 6.4V	30-300	8-80	3	310	3
ANI03-30/MC/ST.	9010330366	Max. 19	2IFpR19/66 2.0Ah 6.4V	30-300	8-80	3	310	3

Page 2 of 5

This CB Test Certificate is issued by the National Certification Body

CBS 102263 0046 Rev. 00

Date, 2025-01-24

(Yin Ji)

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

ANI01-30/MC/ST	9010330366	Max. 19	2IFpR19/66 2.0Ah 6.4V	30-300	8-80	3	310	3
ANI01-30/ST	9010330386	Max. 19	2IFpR19/66 2.0Ah 6.4V	30-300	8-80	3	310	3
ANI03-15/MC/ST.	9010310166	Max. 19	2IFpR19/66 2.0Ah 6.4V	30-300	8-80	3	310	1.5
ANI03-30/ST.	9010330386	Max. 19	2IFpR19/66 2.0Ah 6.4V	30-300	8-80	3	310	3
ANI03-15/ST.	9010310186	Max. 19	2IFpR19/66 2.0Ah 6.4V	30-300	8-80	3	310	1.5
ANI03-30/MC/DA	9010330367	Max. 19	2IFpR19/66 2.0Ah 6.4V	30-300	8-80	3	310	3
ANI03-15/MC/DA	9010310167	Max. 19	2IFpR19/66 2.0Ah 6.4V	30-300	8-80	3	310	1.5
ANI03-30/DA	9010330387	Max. 19	2IFpR19/66 2.0Ah 6.4V	30-300	8-80	3	310	3
ANI03-15/DA	9010310187	Max. 19	2IFpR19/66 2.0Ah 6.4V	30-300	8-80	3	310	1.5
ANI05-30/MC	9010530465	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	30-300	13-130	5	310	3
ANI08-15/MC	9010810465	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	30-300	13-130	5	310	1.5
ANI05-15/MC	9010510365	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	30-300	13-130	5	310	1.5
ANI05-30	9010530485	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	30-300	13-130	5	310	3
ANI08-15	9010810485	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	30-300	13-130	5	310	1.5
ANI05-15	9010510385	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	30-300	13-130	5	310	1.5
ANI04-30LFP7304-S20	9010530485	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	30-300	13-130	5	310	3
ANI05-30/MC/ST	9010530466	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	30-300	13-130	5	310	3
ANI08-15/MC/ST	9010810466	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	30-300	13-130	5	310	3
ANI05-15/MC/ST	9010510366	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	30-300	13-130	5	310	1.5
ANI05-30/ST	9010530486	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	30-300	13-130	5	310	3
ANI08-15/ST	9010810486	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	30-300	13-130	5	310	1.5
ANI05-15/ST	9010510386	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	30-300	13-130	5	310	1.5
ANI05-	9010530467	Max. 21	2IFpR19/66-2	30-300	13-130	5	310	3

Page 3 of 5

This CB Test Certificate is issued by the National Certification Body

CBS 102263 0046 Rev. 00

Date, 2025-01-24


(Yin Ji)

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

30/MC/DA			4.0Ah 6.4V					
ANI08-15/MC/DA	9010810467	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	30-300	13-130	5	310	1.5
ANI05-15/MC/DA	9010510367	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	30-300	13-130	5	310	1.5
ANI05-30/DA	9010530487	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	30-300	13-130	5	310	3
ANI08-15/DA	9010810487	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	30-300	13-130	5	310	1.5
ANI05-15/DA	9010510387	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	30-300	13-130	5	310	1.5
AI03-30/MC	9000330365	Max. 19	2IFpR19/66 2.0Ah 6.4V	20-55	45-125	3	60	3
AI03-15/MC	9000310165	Max. 19	2IFpR19/66 2.0Ah 6.4V	20-55	45-125	3	60	1.5
AI01-30/MC	9000330365	Max. 19	2IFpR19/66 2.0Ah 6.4V	20-55	45-125	3	60	3
AI01-30	9000330385	Max. 19	2IFpR19/66 2.0Ah 6.4V	20-55	45-125	3	60	3
AI03-30	9000330385	Max. 19	2IFpR19/66 2.0Ah 6.4V	20-55	45-125	3	60	3
AI03-15	9000310185	Max. 19	2IFpR19/66 2.0Ah 6.4V	20-55	45-125	3	60	1.5
AI03-30/MC/ST.	9000330366	Max. 19	2IFpR19/66 2.0Ah 6.4V	20-55	45-125	3	60	3
AI01-30/MC/ST	9000330366	Max. 19	2IFpR19/66 2.0Ah 6.4V	20-55	45-125	3	60	3
AI01-30/ST	9000330386	Max. 19	2IFpR19/66 2.0Ah 6.4V	20-55	45-125	3	60	3
AI03-15/MC/ST	9000310166	Max. 19	2IFpR19/66 2.0Ah 6.4V	20-55	45-125	3	60	1.5
AI03-30/ST.	9000330386	Max. 19	2IFpR19/66 2.0Ah 6.4V	20-55	45-125	3	60	3
AI03-15/ST	9000310186	Max. 19	2IFpR19/66 2.0Ah 6.4V	20-55	45-125	3	60	1.5
AI03-30/MC/DA	9000330367	Max. 19	2IFpR19/66 2.0Ah 6.4V	20-55	45-125	3	60	3
AI03-15/MC/DA	9000310167	Max. 19	2IFpR19/66 2.0Ah 6.4V	20-55	45-125	3	60	1.5
AI03-30/DA	9000330387	Max. 19	2IFpR19/66 2.0Ah 6.4V	20-55	45-125	3	60	3
AI03-15/DA	9000310187	Max. 19	2IFpR19/66 2.0Ah 6.4V	20-55	45-125	3	60	1.5
AI02-30LFP7302-S20	9000330385	Max. 19	2IFpR19/66 2.0Ah 6.4V	20-55	45-125	3	60	3

Page 4 of 5

This CB Test Certificate is issued by the National Certification Body

CBS 102263 0046 Rev. 00

Date, 2025-01-24

(Yin Ji)

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

AI05-30/MC	9000530465	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	20-55	73-200	5	60	3
AI05-15/MC	9000510365	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	20-55	73-200	5	60	1.5
AI05-30	9000530485	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	20-55	73-200	5	60	3
AI05-15	9000510385	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	20-55	73-200	5	60	1.5
AI05-30/MC/ST	9000530466	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	20-55	73-200	5	60	3
AI05-15/MC/ST	9000510366	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	20-55	73-200	5	60	1.5
AI05-30/ST	9000530486	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	20-55	73-200	5	60	3
AI05-15/ST	9000510386	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	20-55	73-200	5	60	1.5
AI05-30/MC/DA	9000530467	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	20-55	73-200	5	60	3
AI05-15/MC/DA	9000510367	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	20-55	73-200	5	60	1.5
AI05-30/DA	9000530487	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	20-55	73-200	5	60	3
AI05-15/DA	9000510387	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	20-55	73-200	5	60	1.5
AI04-30LFP7304-S20	9000530465	Max. 21	2IFpR19/66-2 4.0Ah 6.4V	20-55	73-200	5	60	3

Page 5 of 5

This CB Test Certificate is issued by the National Certification Body

CBS 102263 0046 Rev. 00

Date, 2025-01-24


(Yin Ji)

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore